

The Periodical Surveys for Emergency Fire Pumps

Amended Rules and Guidance

Rules for the Survey and Construction of Steel Ships Part B
Guidance for the Survey and Construction of Steel Ships Part B

Reason for Amendment

In recent years, there have been many reported cases of problems with Emergency Fire Pumps that are the direct result of poor maintenance. In many of these cases, the problems were so minor that they could have been easily avoided by performing simple maintenance on site.

Emergency Fire Pumps are required to be promptly activated without fail in the event of a fire which means that they need to be kept in good working condition at all times. Therefore, relevant requirements have been added regarding the maintenance of Emergency Fire Pumps.

Outline of Amendment

Relevant requirements have been added regarding the maintenance of Emergency Fire Pumps.